

RoHS 🗸

Via D. Alighieri 33 29010 Villanova sull'Arda (PC) - Italy Tel. 0039.0523.837899 Fax 0039.0523.837381



UNI EN ISO 9001-2015 Certified Company





K-FLEX 2015 CONTROL

Description:	Multi-conductors power supply, connecting and control cable with colour code cores for a working voltage of 300/500 V.	
Design:		
Construction:	Flexible bare copper conductors acco	rding to CEI 20-29 Class 5 and DIN-VDE 0295
	K5	
	PVC Insulation compound type TI1 according to CEI 20-11 and VDE 0207 with	
	special mechanical resistance. Coloured code as HD 308 S2 and VDE 0293	
	Outer jacket in PVC TM2 according to CEI 20-11 and VDE 0207	
Manufacturing's	Test and Control according to our certificated ISO 9001-2015 CSQ-IMQ (EQ-	
Controls:	NET) Quality System procedure.	
	Labor tests reports are stored in our internal Q.C. laboratory archive together with	
	the production reports)	
Norms:	Flame retardant, Test method B according to DIN VDE 0472 part 804 and IEC	
	60332-1	
	Based on IEC 60227-5 HD 21.5 S3 - VDE 0281 / 5 - HD 21.13 S1 - VDE 0281 / 13	
	The cable is conform to Low Voltage Directive (LVD) 2014/35/EU CE	
Technical dates:	Nominal voltage:	300/500V
	 Spark Test voltage: 	3000 V
	Working temperature:	Occasional flexing: -5°C to +70°C
		Fixed installation: -40°C to +80°C
	 Minimum bending radius 	Occasional flexing: 15 x outer Ø
		Fixed installation: 4 x outer $Ø$
Use:	The range of application comprises all electrical installations in dry and damp	
	interiors, especially under industrial conditions, outdoor use only with UV protection and in observance of the temperature range. These cables are suitable for free not continuously movement appliance without tensile load or compulsory guidance as well	
	as for fixed installation.	