



K-FLEX 3000 H.F. OIL UL CSA

Description : High oil resistant Halogen free multi cores flexible control and power supply cable for working voltage of 300/500 V.

Design:



Construction : Flexible bare copper conductors according to CEI 20-29 Class 5 and DIN-VDE 0295 K5
Halogen free insulation compound type **TI6** according to HD 21.14 S1 annex A
Black numbered cores with or without green yellow core
Special halogen free, oil resistant, jacket compound type **TM7** according to HD 21.14 S1 annex B

Manufacturing's Controls: Test and Control according to our certificated **ISO 9001-2015 CSQ-IMQ (EQ-NET)** Quality System procedure.
Labor tests reports are stored in our internal Q.C. laboratory archive together with the production reports

Norms : Flame-retardant according to IEC 60332-1-2 (flame spread on a single cable)
No flame-propagation according to IEC 60332-3-24 respectively IEC 60332-3-25 (Flame spread on vertical cable or wire bundle)
Halogen-free according to IEC 60754-1 (amount of halogen acid gas)
Corrosiveness of combustion gases according to IEC 60754-2 (degree of acidity)
Low smoke density according to IEC 61034-2
Oil-resistant according to EN 50363-4-1 (TM5)
According to UL style 10615 and 21217 and CSA-AWM I A/B II A/B
The cable is conform to Low Voltage Directive (LVD) 2014/35/EU CE

Technical dates :

- Nominal voltage : 600 V
- Spark Test voltage : 6000 V
- Working temperature : Occasional flexing: -15°C to +75°C
Fixed installation: -40°C to +75°C
- Minimum bending radius Occasional flexing: 15 x outer Ø
Fixed installation: 4 x outer Ø

Use : Environmentally friendly, halogen-free Control Cable especially for electrical equipment and installations in industrial environments, dry or damp interiors.
Suitable for fixed installation under medium mechanical load conditions as well as for flexing application at free, non-continuously recurring movement without tensile load or compulsory guidance. Not suitable for direct burial.
Particularly suitable where human and animal life as well as valuable property are exposed to high risk of fire hazards