

Via D. Alighieri 33 29010 Villanova sull'Arda (PC) - Italy Tel. 0039.0523.837899 Fax 0039.0523.837381

Data Sheet

UNI EN ISO 9001-2015 Certified Company









K-FLEX 3000 S H.F. UL

Description: American, Halogen Free, Armoured, Control and Power supply Cables manufactured

according to UL AWM Style 21217.

Design:



Flexible bare copper conductors according to CEI 20-29 Class 5 and DIN-VDE 0295 K5 Construction:

> Halogen Free FR PE Insulation compound according to UL 1581 Inner sheath in special FR PE Compound according to UL 1581

Steel wires braiding with coverage 65% ± 5%

Outer sheath in special FR PE Compound according to UL 1581

Manufacturing's

Controls:

Test and Control according to our certificated ISO 9001-2015 CSQ-IMQ (EQ-

NET) Quality System procedure.

Labor tests reports are stored in our internal Q.C. laboratory archive together with

the production reports

Norms: Flame-retardant according to IEC 60332-1-2

No flame-propagation according to IEC 60332-3-24 respectively IEC 60332-3-25

Halogen-free according to IEC 60754-1

Corrosiveness of combustion gases according to IEC 60754-2

Low smoke density according to IEC 61034 Construction according to UL AWM Style 21217

The cable is conform to Low Voltage Directive (LVD) 2014/35/EU CE

Technical dates:

Nominal voltage: 600 V

5000 V Spark Test voltage:

Occasional flexing: -15°C to +75°C Working temperature:

Fixed installation: -40°C to +75°C Occasional flexing: 20 x outer Ø

Minimum bending radius

Fixed installation: $6 \times \text{outer } \emptyset$

Use:

Environmentally friendly, halogen-free Control Cable especially for electrical equipment and installations in industrial environments, dry or damp interiors.

Suitable for fixed installation under medium mechanical load conditions as well as for flexing application at free, non-continuously recurring movement without tensile load or compulsory guidance. Outdoor use with UV-protection only, considering the temperature range. Not for direct burial.

Particularly where human and animal life as well as valuable property are exposed to high risk of fire hazards

06 August 2019