



K-FLEX 7500 CY TC ER XHHW-2 UL

Description : EMC compliant, Shielded, XLPE Insulated, increased oil-resistant control and power supply cables, conforming to NFPA 79 2007 wiring norms and NEC 336.10(7) manufactured according to UL 1277 (Tray cable - Exposed run - Oil resistant).

Design:



Construction : Cores type UL Listed XHHW-2 for bigger sizes
 Flexible bare copper conductors according to CEI 20-29 Class 5, DIN-VDE 0295 K5 and UL 83 standard
 Special Flame retardant XLPE Insulation compound UL approved type XHHW-2
 Polyester tape
 Tinned copper screening with coverage 85% ± 5%
 Outer sheath in special PVC according to UL 1277 and UL 1063

Manufacturing's Controls: Test and Control according to our certificated **ISO 9001-2015 CSQ-IMQ (EQ-NET)** Quality System procedure.
 Labor tests reports are stored in our internal Q.C. laboratory archive together with the production reports

Norms : Flammability of Cable according category FT4/IEEE of Vertical-Tray Fire-Propagation and Smoke-Release Test for Electrical and Optical-Fiber Cables, UL 1685 standard.
 Construction according to UL 1277 (Oil-resistant according to UL OIL RES I and Water-resistant, UL Wet Approval 75 °C)
 The cable is conform to Low Voltage Directive (LVD) 2014/35/EU CE

Technical dates :

- Nominal voltage: 600 V
- Spark Test voltage: 6000 V
- Fixed installation working temperature: -40°C to + 90°C
- Occasional flexing working temperature: -25°C to + 90°C
- Fixed installation minimum bending radius = 6 x cable Ø
- Occasional flexing minimum bending radius = 20 x cable Ø

Use : Efficient stocking! These control cables are especially suitable for export-orientated machinery. It is suitable for control equipment on machine tools subjected to medium mechanical stresses, for fixed or flexible installation, where free movement is required without tensile stresses and without forced guidance systems, in dry, damp and wet interiors (including water-oil mixtures).
 TC-ER (Tray Cable Exposed Run) approval for open wiring between cable tray and industrial machines/plants acc. to NEC 336.10(7)
 Class 1, Div. 2 in accordance with NEC "National Electrical Code" Art. 336, 392, 501